

PROJECT INSPECTION REPORT

Division 9: Floor & Deck System



Manufacturer of

U.S. SPECIALTY COATINGS

MONOPOLE, INC
U.S. SPECIALTY COATINGS
4661 ALGER ST., LOS ANGELES, CA 90039
TEL: (818) 500-8585 FAX: (818) 502-0818

All Substrates Must Be Inspected Prior to the Application of the below Mentioned Products

DATE: _____

JOB REFERENCE: _____

ADDRESS: _____

APPLICATOR: _____

INSPECTED BY: _____ COMPLETION DATE: _____

MONOCHEM PRODUCT(S)/SYSTEMS USED

List Quantities

System 200

Monochem 21 (primer) : _____

Monochem 310 (base coat) : _____

Monochem 610 (top coat) : _____

Permashield 2000 (top coat) : _____

System 330

Ultra-Prime/M21 (primer): _____

Monochem 300 (base coat): _____

Dex-Coat (top coat): _____

Permashield 200 (top coat): _____

Note if different top coats were used and associated quantities

List Square Footage

System 200

Monochem 21 (primer) : _____

Monochem 310 (base coat) : _____

Monochem 610 (top coat) : _____

Permashield 2000 (top coat) : _____

System 330

Ultra-Prime/M21 (primer): _____

Monochem 300 (base coat): _____

Dex-Coat (top coat): _____

Permashield 200 (top coat): _____

Approximate Square Footage of Ramp Areas: _____

Note if different top coats were used and associated quantities

PROJECT SQUARE FOOTAGE: _____

SUBSTRATE: _____

SECTION 1: Bare Surface Condition (pre-application)

1. Is the proper slope of 1/4" per foot?
 Yes No

2. Is the surface below 15% moisture (13% for wood)?
 Yes No

3. Is the surface spalling or displaying cracks larger than 1/16"?
 Yes No

*If yes, will these imperfections be fixed prior to product application?
 Yes No

4. Does the cementitious surface have adequate profile of at least 220 grit?
 Yes No

5. Are there any signs of hydrostatic pressure?
 Yes No

6. Is the surface elevated?
 Yes No

*If the surface is elevated, will all the moisture exposed sides (underside, vertical lips, ect.) be sealed from moisture?
 Yes No

7. Are any parts of the application butted up against a wall?
 Yes No

*If yes, will the base 2 inches of the wall be coated with the recommended system?
 Yes No

8. Will the coatings be applied after all trade work has been completed?
 Yes No

9. Has the test patch(es) passed the required adhesion testing?
 Yes No

SECTION 2: Painted Surface Condition (pre-application)

1. Is there proper slope of 1/4" per foot?
 Yes No

2. Is the surface below 15% moisture (13% for wood)?
 Yes No
3. Is the surface spalling or displaying cracks larger than 1/16"?
 Yes No
4. Are there any signs of hydrostatic pressure?
 Yes No
5. Is the surface elevated?
 Yes No
- *If the surface is elevated, will all the moisture exposed sides (underside, vertical lips, ect.) be sealed from moisture?
 Yes No
- *If elevated, is there an existing sound membrane?
 Yes No
6. Are any parts of the application butted up against a wall?
 Yes No
- *If yes, will the base 2 inches of the wall be coated with the recommended system?
 Yes No
7. Will the coatings be applied after all trade work has been completed?
 Yes No
10. Are there any blisters, splits, buckles, punctures, loose areas or other signs of physical damage to the existing painted surface?
 Yes No
11. Is the existing coating water base, oil base, unknown or other?
 Water Base Oil Base Unknown Other
12. Will the existing coating be sanded dull prior to the application of Monochem Coatings?
 Yes No
13. Is there any evidence of contamination?
 Yes No
14. Is there any evidence of standing water?
 Yes No
15. Has the test patch(es) passed the required adhesion testing?
 Yes No

SECTION 3: Post Application Condition

1. Was the surface preparation sound?
 Yes No

2. Was enough material used to meet the specifications?
____ Yes ____ No

SECTION 4: Structural Conditions

1. Substrate: (specify)_____
2. Is there efflorescence: Yes____ No____
*If yes, will the efflorescence be cleaned prior to application? Yes____ No____
3. Is there structural cracking or spalling? List the type and location:_____
- _____
4. Are the expansion or control joints caulked? Yes____ No____
5. Are the flashing & scuppers installed? Yes____ No____
6. Are the parapet walls that come into contact with the coatings sealed? Yes____ No____ N/A ____
7. Are the below grade walls waterproofed? Yes____ No____ N/A____
8. Was a moisture reading conducted? If so, list result:_____
9. Surface Dry, Clean, & Ready For Coating: Yes____ No____ Other_____

COMMENTS & OBSERVATIONS

Include any necessary corrections needed to qualify for a warranty:

Project Inspector:_____

Company:_____ Date Inspected:_____

Monopole Authorized Signature:_____ Date:_____

This report must be submitted to Monopole, Inc. for WARRANTY approval.
For all warranty requests, please fill-out the *Warranty Information Page*.