



Manufacturer of  
**U.S. SPECIALTY COATINGS**

## **DIVISION 7: WATER REPELLENTS**

### **PREPARATION FOR PROJECT INSPECTION REPORT**

*FOR WARRANTY APPROVAL, PRODUCTS COVERED UNDER THE  
INSPECTION REPORT ARE:*

- ❖ **AQUASEAL REGULAR**
- ❖ **AQUASEAL HEAVY DUTY**
- ❖ **AQUASEAL SEMI GLOSS**
- ❖ **AQUASEAL M.E.**
- ❖ **AQUASEAL SS**
- ❖ **AQUASEAL ME 7**
- ❖ **AQUASEAL ME12**
- ❖ **ELASTOSEAL**
- ❖ **AQUASEAL PAINT ADDITIVE**
- ❖ **AQUASEAL SILANE 20**
- ❖ **AQUASEAL SILANE 40**
- ❖ **AQUASEAL 20**
- ❖ **AQUASEAL 40**
- ❖ **AQUASEAL FORMULA 2000**
- ❖ **AQUAPELL**

1. LIST THE PROPER TYPE OF SUBSTRATE: SPLIT FACE BLOCK, SLUMP BLOCK, SMOOTH BLOCK, CONCRETE BRICK, USED BRICK, STUCCO, TILT-UPS, ETC....
2. CHECK FOR SURFACE CONDITIONS: PARTICULARLY MORTAR JOINTS CRACKS. ALSO CHECK FOR VOIDS AND BEE HOLES OR OTHER STRUCTURAL CRACKS, CLEAR WATERPROOFING WILL NOT PROTECT ANYTHING LARGER THAN HAIRLINE CRACKS. IF CRACKS ARE FOUND BEFORE OR AFTER APPLYING THE WATERPROOFING SEALER, SPECIAL CORRECTIVE STEPS MUST BE TAKEN TO SEAL THEM.
3. LOOK FOR EFFLORESCENCE DEPOSITS WHICH INDICATE MOISTURE PROBLEMS, IDENTIFY PROBLEM AREAS AND CORRECT THEM PRIOR TO APPLYING AQUASEAL.
4. PARAPET WALLS SHOULD HAVE METAL COPINGS TO PREVENT THE ENTRANCE OF MOISTURE AT THE TOP OF WALLS. CLEAR PENETRATING WATERPROOFING PRODUCTS ARE NOT CAPABLE OF HANDLING THE CRACKING AND MOVEMENT ENCOUNTERED WITH MORTAR, MASONRY, AND TAR CAPS. CEMENT COPING, IF USED, MUST HAVE AN ELASTOMERIC SURFACE COATING THAT WILL WITHSTAND THE MOVEMENT AND CRACKING WHILE STILL MAINTAINING A WATERPROOF BARRIER.
5. EXPANSION JOINTS AND OTHER DISSIMILAR MATERIALS MUST BE CAULKED WITH A FLEXIBLE ELASTOMERIC CAULKING THAT WILL ALLOW FOR MOVEMENT. CHECK DOORS, WINDOWS, FLASHING, CAPPING, EXPANSION JOINTS FOR PROPER SPACING. ALL HOLES IN THE MASONRY FOR PIPES, CONDUIT OR DOWNSPOUTS SHOULD BE CAULKED AROUND THEIR PERIMETERS.
6. WHERE THE ROOF ATTACHES TO THE WALLS, FLASHING MUST BE PROPERLY CAULKED. THE WALL MUST BE WATERPROOFED FROM THE CAPPING DOWN TO THE FLASHING.
7. DETERMINE THE PROPER PRODUCT TO BE USED AND THE PROPER COVERAGE AND QUANTITY OF MATERIAL NEEDED. CHECK THE SPECIFIC TYPE OF SUBSTRATE (SMOOTH, DENSE, TEXTURED, FLUTED, RAKED, ETC.).

# PROJECT INSPECTION REPORT

Division 7: Water Repellents

MONOPOLE, INC  
U.S. SPECIALTY COATINGS  
4661 ALGER ST., LOS ANGELES, CA 90039  
TEL: (818) 500-8585 FAX: (818) 502-0818



JOB REFERENCE: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

## AREAS TO BE INSPECTED PRIOR TO APPLICATION OF ANY OF THE ABOVE MENTIONED PRODUCTS

1. Substrate: (specify) \_\_\_\_\_
2. Mortar Joints: Tooled: \_\_\_\_\_ Raked: \_\_\_\_\_ Struck: \_\_\_\_\_ Cracks: Yes: \_\_\_\_\_ No: \_\_\_\_\_  
Condition: \_\_\_\_\_
3. Bee Holes/Voids: Yes \_\_\_\_\_ No \_\_\_\_\_ Condition: \_\_\_\_\_
4. Efflorescence: Yes \_\_\_\_\_ No \_\_\_\_\_ Cleaning Required: Yes \_\_\_\_\_ No \_\_\_\_\_
5. Structural Cracking: Type and Location: \_\_\_\_\_
6. Required Capping Of All Stem Walls & Parapets Installed: Yes \_\_\_\_\_ No \_\_\_\_\_  
Metal: \_\_\_\_\_ Elastomeric: \_\_\_\_\_ Other: \_\_\_\_\_
7. Roof Installed: Yes \_\_\_\_\_ No \_\_\_\_\_ Downspouts Installed: Yes \_\_\_\_\_ No \_\_\_\_\_
8. Caulking Installed: Windows: Yes \_\_\_\_\_ No \_\_\_\_\_ Doors: Yes \_\_\_\_\_ No \_\_\_\_\_
9. Expansion Or Control Joints Caulked: Yes \_\_\_\_\_ No \_\_\_\_\_
10. Flashing & Scuppers Installed: Yes \_\_\_\_\_ No \_\_\_\_\_
11. Parapet Wall (Backside) Waterproofed: Yes \_\_\_\_\_ No \_\_\_\_\_
12. Below Ground Walls Waterproofed: Yes \_\_\_\_\_ No \_\_\_\_\_
13. Building Dry, Clean, & Ready For Sealing: Yes \_\_\_\_\_ No \_\_\_\_\_ Other \_\_\_\_\_
14. Product To Be Used: \_\_\_\_\_
15. Approximate Square Footage Of Surface To Be Sealed: \_\_\_\_\_
16. Approximate Quantity Of Products To Be Used: \_\_\_\_\_

Other Comments Should Be Made On the Back Side of This Form

Project Inspector: \_\_\_\_\_

Company: \_\_\_\_\_ Date Inspected: \_\_\_\_\_

This report must be submitted to Monopole, Inc. for WARRANTY approval.  
For all warranty requests, please fill-out the *Warranty Information Page*.